Mr. Jack Broadbent Director of Air Management Division **United States Environmental Protection Agency** 75 Hawthorne Street San Francisco, CA 94105

Calpine Gilroy Cogen, L.P. – Facility #B1180

Significant Permit Revision and Issuance of Acid Rain Permit

ALAMEDA COUNTY Roberta Cooper Scott Haggerty (Vice-Chairperson) Nate Miley Shelia Young

Dear Mr. Broadbent:

**CONTRA COSTA** COUNTY Mark DeSaulnier Mark Ross Gayle Uilkema

This is to advise you that the Bay Area Air Quality Management District has decided to issue a significant revision to the Major Facility Review Permit for Calpine Gilroy Cogen, L.P (Facility Number B1180) and issue an acid rain permit.

MARIN COUNTY Harold C. Brown, Jr. The purpose of this project is to install three 45 MW turbines for the purpose of generating electricity, to change the existing permit conditions to allow installation of the project, and to issue an acid rain permit to the facility.

NAPA COUNTY Brad Wagenknecht

The following changes were also made:

## SAN FRANCISCO

The existing cooling tower (S-104) was added to the permit since it is no longer exempt.

COUNTY Chris Dalv Tony Hall Leland Yee

Regulation 6-310 has been added for S-104.

SAN MATEO COUNTY Jerry Hill

The citation of Regulation 6-301 and 6-310 has been corrected in Section IV and Section VII.

Marland Townsend (Secretary)

The basis was corrected for Condition 18102, parts 22, 24, 25, 26, 30, 31, 32 and 35.

SANTA CLARA COUNTY

A final copy of the revised Major Facility Review/Acid Rain Permit is enclosed for your information. If you have any questions on this matter, please call **Steve** Hill, Air Quality Manager, at (415) 749-4673.

Randy Attaway (Chairperson) Liz Kniss Julia Miller Dena Mossar

Very truly yours,

SOLANO COUNTY William Carroll

> Ellen Garvey Executive Officer/

SONOMA COUNTY Tim Smith Pamela Torliatt

Air Pollution Control Officer

Ellen Garvey **EXECUTIVE OFFICER/ AIR POLLUTION** CONTROL OFFICER

EG:SAH:myl

Enclosures

h:\pub\_data\titlev\permit\Significant\01Oct\B1180signif.doc